

Transition Plan Section 504/ADA Compliance

All facilities (Dixie County Courthouse and all county owned public buildings) were certified as handicapped accessible and in-compliance as of 11/02/2006. Only County facilities constructed or acquired since that date were evaluated and incorporated into this Transition Plan.

FACILITY:	Suwannee Technical Center	
OBSTACLE:	ACCESSIBILITY METHOD:	SCHEDULE:
No grab bars in Restroom	Install pull/grab bars in restroom	March 2017
Door knobs are not ADA throughout facility	Replace with ADA compliant door knobs	March 2017
Hand Rail on ramp is too high	Lower hand rail on ramp	March 2017
Restroom not signed	Install ADA compliant sign at 60"	March 2017

FACILITY:	Jena Technical Center	
OBSTACLE:	ACCESSIBILITY METHOD:	SCHEDULE:
Restroom door knob not ADA	Replace with ADA compliant door knob	March 2017
Restroom signed incorrectly	Install ADA compliant sign at 60"	March 2017
No ADA Parking space	Construct 1 ADA parking space	June 2017

FACILITY:	Dixie County Emergency Operations Center	
OBSTACLE:	ACCESSIBILITY METHOD:	SCHEDULE:
This facility is fully accessible and in compliance.		

FACILITY:	Women's Center	
OBSTACLE:	ACCESSIBILITY METHOD:	SCHEDULE:
No ADA Parking space	Stripe and sign existing parking stall to meet ADA requirements	March 2017
Front door knob not ADA	Replace with ADA compliant door knob	March 2017
Restroom door knob not ADA	Replace with ADA compliant door knob	March 2017
Restroom not properly signed	Move the existing restroom sign to be ADA compliant	March 2017
No Emergency Exit signs	Install ADA compliant emergency exit signs	March 2017

This Transition Plan has been approved and adopted this 17th day of November 2016.



 Ronnie Edmonds, Commission Chairman

Attest:



 Dana Johnson, Clerk

